

(NASA-FC-10,000) SUPPORT OF THE EIGHT-FOOT  
HIGH-TEMPERATURE TUNNEL MODIFICATIONS  
PROJECT Final Report. 16 May 1985 - 15 May  
1986 (Old Dominion Univ.) 3 F CSCL 14B

N89-12572

Unclas  
G3/09 0114973

DEPARTMENT OF ELECTRICAL & COMPUTER ENGINEERING  
COLLEGE OF ENGINEERING AND TECHNOLOGY  
OLD DOMINION UNIVERSITY  
NORFOLK, VIRGINIA 23508

**SUPPORT OF THE EIGHT-FOOT HIGH-TEMPERATURE TUNNEL  
MODIFICATIONS PROJECT**

By

Donald Y. Hodges, Graduate Research Assistant

and

John V. Shebalin, Principal Investigator

Final Report  
For the period May 16, 1985 to May 15, 1986

Prepared for the  
National Aeronautics and Space Administration  
Langley Research Center  
Hampton, Virginia 23665

Under  
**NASA Contract NAS1-17993**  
**Task Authorization No. 6**  
A. J. Zuckerwar, Technical Monitor

**Submitted by the**  
**Old Dominion University Research Foundation**  
**P.O. Box 6369**  
**Norfolk, Virginia 23508**

December 1987

## **SUPPORT OF THE EIGHT-FOOT HIGH-TEMPERATURE TUNNEL MODIFICATIONS PROJECT**

By

Donald Y. Hodges<sup>1</sup> and John V. Shebalin<sup>2</sup>

### **SUMMARY**

During the term of the task, an ultrasonic level sensor was developed to measure the liquid level in a storage vessel under high pressures, namely up to 6000 psi. The sensor is described in Ref. 1 (copy of reprint attached). A prototype sensor has been installed in the cooling-water storage vessel of the Eight-Foot High-Temperature Tunnel. Plans are being made to install the readout instrument in the control room, so that tunnel operators can monitor the water level during the course of a tunnel run.

It was discovered that the sensor will operate at cryogenic temperatures. Consequently, a sensor will be installed in the modified Eight-Foot High-Temperature Tunnel to measure the sound speed of liquid oxygen (LOX) as it is transferred from a storage vessel to the tunnel combustor at pressure of about 3000 psi. The sound speed is known to be a reliable indicator of contamination of LOX by pressurized gaseous nitrogen (Ref. 2), which will be used to effect the transfer. Subjecting the sensor to a temperature cycle from room temperature to liquid nitrogen temperature and back again several times revealed no deterioration in sensor performance. The method using this sensor is superior to the original method, which was to bleed samples of LOX from the storage vessel to an independent chamber for measurement of the sound speed.

---

<sup>1</sup>Graduate Research Assistant, Department of Electrical & Computer Engineering, Old Dominion University, Norfolk, VA 23508.

<sup>2</sup>Professor, Department of Electrical & Computer Engineering, Old Dominion University, Norfolk, VA 23508.

## REFERENCES

1. A.J. Zuckerwar, D.S. Mazel and D.Y. Hodges, "Ultrasonic level sensor for liquids under high pressure," Rev. Sci. Instrum. 57, 2318-2320 (1986).
2. A.J. Zuckerwar and D.S. Mazel, "Sound speed measurements in liquid oxygen-liquid nitrogen mixtures," NASA TP 2464 (1985).